



एसजेवीएन लिमिटेड  
सतर्कता विभाग, निगमित मुख्यालय  
शक्ति सदन, शनान, शिमला - 171006

(Our shared Vision: 25000 MW by 2030 & 50000 MW by 2040)

Ref No.: SJVN/CHQ/Circular- 160

Date: 25.04.2024


**System Circular**

Any deviation without the approval from Competent Authority is a contractual violation. It is imperative that all the technical specifications, which are agreed while signing of contract agreement between employer and contractor, are strictly adhered to during execution of the contract by Engineering team, site execution team, Quality Assurance team or any other team to whom it pertains. As such, post award contractual deviation in scope of work (either in quantity / specification) be minimised. The above is emphasized upon since in one of the inspection, it has been found that ***underground neutral earthing of power transformers was done using GI strips instead of the specified copper flat strips as per Terms & Conditions of Contract Agreement.***

However, if technological issue / site issue / design issue/ any other issue demands for any deviation after award of work, then the proposed deviation vis-a-vis contractual provision is required to be deliberated, justifications to be recorded in writing in detail with proper detailed financial analysis before taking final decision. Approval in such cases need to be obtained from the Competent Authority after bringing all the facts of the matter in writing to him / her.

Strict compliance must be ensured by all concerned.

This issues with the approval of CMD.

  
(अनिल कुमार गोयल)  
उप-मुख्य सतर्कता अधिकारी  
एसजेवीएन

वितरण सूची संलग्न:



**वितरण:**

**शिमला कार्यालय:**

**विभागाध्यक्ष:** सिविल संविदा/ निगम अनुवीक्षण एवं समन्वय/ वित्त एवं लेखा/ आई.टी. एवं एस.ई / गु.आ.एवं निरीक्षण/विद्युत संविदा विभाग/ बी.डी.ई/ सी.एवं एस.ओ./विद्युत अभिकल्प/ सिविल डिजाईन /एच.आर./ वास्तुकला एवं सर्वेक्षण ईकाई / आंतरिक लेखा /कंपनी सचिव /सी.एफ.एम.डी./ (भू-विज्ञान)।

**कार्यकारी निदेशक :** संपर्क कार्यालय, दिल्ली ।

**मुख्य कार्यकारी अधिकारी:** एसजीईएल/एसटीपीएल/एसएपीडीसी।

**परियोजना प्रमुख:** एनजेएचपीएस/आरएचपीएस/एलएचईपी स्टेज-I/सुन्नी डैम एचईपी/एलएचईपी स्टेज-II/धौलासिद्ध एचईपी/चिनाब परियोजनाएं/जांगी थोपन पोवारी एचईपी/ एनएमएचईपी/ जेएसएचईपी/देवसरी एचईपी/खिरविरे परियोजना/सादला एसपीपी/चरंका एसपीपी/प्रासन सोलर परियोजना/गुजराह एवं गुजरई एसपीपी/ओंकारेश्वर एसपीपी/गुजरात एसपीपी/बीकानेर एसपीपी/ बिहार परियोजनाएं/पंजाब परियोजनाएं।

**प्रतिलिपि सादर सूचनार्थ हेतु:**

मुख्य सतर्कता अधिकारी, एसजेवीएन लिमिटेड।